

C. 15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F-6/DFS/MS/2023/School/WZ/311

Dated: 08/05/2023

FIRE SAFETY CERTIFICATE

Certified that the Rajdhani Public School located at Kureni Road, Narela Delhi-110040 comprised of **Ground and Two upper floors** owned/occupied by Rajdhani Public School was issued FSC by this department vide letter No F-6/DFS/MS/2018/School/WZ/359 dated 06/03/2018. The building was inspected by the officer concerned of this department on 21/04/2023 in the presence of Sh. Abbas Ali (Manager), and observed that all the fire prevention and fire safety arrangements as provided in the building found in good working condition. The premises have deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy **Group B Educational** with effect from 08/05/2023 for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 08/05/2023 at New Delhi, by


(Atul Singh)
Director


Ph 011-23414000


Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54
2. The Principal, Rajdhani Public School, Kureni Road, Narela, Delhi-40

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in


MANAGER
RAJDHANI PUBLIC SCHOOL
NARELA, DELHI - 110040


Vice Principal
Rajdhani Public School
Kureni Marg, Narela, Delhi-40

INSPECTION REPORT

1. Name & address of the building : Rajdhani Public School located at Kureni Road, Narela, Delhi-110040
 2. Type of Occupancy : Educational
 3. Building Comprised : Ground + Two Upper Floors
 4. Type of Case : Renewal
 5. Details of Previous NOC : F6/DFS/MS/2018/School/WZ/359 dated- 06/03/2018
 6. Fire Safety directives letter No : As Per N-6
 7. Date of inspection : 21/04/2023
 8. Name of Inspecting Officer : ADO, R.K.Sinha
 9. Name and designation of officers :
 From the building side : Sh. Abbas Ali (Manager)
 10. Year of Construction : 1995
 11. Applicant's letter No : Outdoor Diary No. 191 . Dated-10/04/2023

S. No.	Minimum Standards on fire prevention and fire safety UR 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06 m	06 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	04	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m	1.50 m, 1.10 m, 0.75 m & 1.20m (iron staircase)	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
		01	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
		NA	NA	NA
	Smoke Management System			
	• Basements	NA	NA	NA


MANAGER

RAJDHANI PUBLIC SCHOOL
NARELA, DELHI - 110040



Vice-Principal
Rajdhani Public School
Kureni Marg, Narela, Delhi-40

	• Upper floors	12 a/c per hour	Natural Ventilated	MR
	Fire Extinguishers			
	• Total numbers	05	15	MR
	• Types	ABC/Co2	ABC/Co2	MR
	• IS marking	Yes	Yes	MR
	First-Aid Hose Reels			
	• Total numbers on each floor	01 Nos.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA

9

Handwritten signature


MANAGER
RAJDHANI PUBLIC SCHOOL,
NARELA, DELHI - 110040


Handwritten mark

Handwritten signature

Vice Principal
Rajdhani Public School
Kureni Marg, Narela, Delhi-40

€	Pump House Access	NA	NA	NA
	• Terrace level	-	-	-
	• Discharge of pump	450 lpm	Provided	MR
	• Head of the pump	40 m	40 m	MR
	• Power Supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	• Draw-off connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	• Total Area	NA	NA	NA
	• Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA


 MANAGER
 RAJDHANI PUBLIC SCHOOL
 NARELA, DELHI - 110040


 Vice Principal
 Rajdhani Public School
 Kureni Marg, Narela, Delhi-40