



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
NARELA ZONE

No. DHO/NRZ/2024/D- 546

Dated: 30/09/2024

SCHOOL HEALTH CERTIFICATE

Date of Inspection : 27.09.2024

1. Name of School : RAJDHANI PUBLIC SCHOOL
2. Address : Kureni Road, Narela, Delhi – 110040
3. No. of Shifts : One Timing 08:00 AM to 02:00 PM

Accommodation Provided

THE FLOOR AREA IN THE CLASSROOM IS SUFFICIENT.

THE CLASSES ARE WELL LIGHTED.

THE CLASSROOMS ARE WELL VENTILATED.

THE CLASSROOMS ARE KEPT NEAT AND CLEAN.

THE DRINKING WATER IS WATER TEST REPORT APPROVED BY BTH Lab..


THE TOILET ARRANGEMENT IS SANITARY & HYGENIC AND SUFFICIENT IN NUMBER.

Remarks :

THIS CERTIFICATE DOES NOT INDICATE PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for a period of one year from the date of issue.

The Manager
Rajdhani Public School
Kureni Road, Narela, Delhi – 110040


Dy. Health Officer
Narela Zone
Dy. Health Officer
Narela Zone


 ULR No. TC900023000000161F
 Test Report No. TR320230609650

 Page 2 of 2
 Date: 07/09/2024

S. No.	Test & Clause reference	Requirement as per IS 10500:2012 With amendment No. 1, 2, 3 & 4		Test Results/ Observations
		Requirement (Acceptable Limit)	Requirement limit In the absence of alternate source	
A	Organoleptic and Physical Parameter (Table 1)			
1	Colour Cl.4, Table 1, S.No.(i) of IS 10500:2012 & IS 3025-4:1983	5 Hazen units Max.	15 Hazen units Max.	< 5 Hazen units
2	Odour Cl.4, Table 1, S.No. (ii) of IS 10500:2012 & IS 3025-5:2018	Agreeable	Agreeable	Agreeable
3	pH value Cl.4-Table-1, S.No. (iii) of IS 10500:2012 & IS 3025-11:1983	6.5 – 8.5	No relaxation	7.8
4	Taste Cl. 4, Table 1, S.No. (iv) of IS 10500:2012 & IS 3025-8:1984	Agreeable	Agreeable	Agreeable
5	Turbidity Cl.4, Table 1, S.No. (v) of IS 10500:2012 & IS 3025-10:1984	1 NTU Max.	5 NTU Max.	< 1 NTU
6	Total Dissolved Solids Cl.4, Table 1, S.No. (vi) of IS 10500:2012 & IS 3025-16:1984	500 mg/l Max.	2000 mg/l Max.	102 mg/l
B	General Parameters Concerning Substance Undesirable in Excessive Amounts (Table 2)			
1	Chloride (as Cl) Cl. 4, Table 2, S.No. (viii) of IS 10500:2012 & IS 3025-32:1988	250 mg/l Max.	1000 mg/l Max.	8.5 mg/l
2	Fluoride (as F) Cl. 4, Table 2, S.No. (x) of IS 10500:2012 & IS 3025-60:2008	1.0 mg/l Max.	1.5 mg/l Max.	Not detected
3	Iron (as Fe) Cl. 4, Table 2, S.No. (xii) of IS 10500:2012 & IS 3025-53:2003	0.3 mg/l Max.	No relaxation	Not detected
4	Total hardness (as CaCO ₃) Cl. 4, Table 2, S.No. (xxiii) of IS 10500:2012 & IS 3025-21:2009	200 mg/l Max.	600 mg/l Max.	78.3 mg/l

End of Document



The NABL Accreditation claimed is valid only for the scope of accreditation as on date of this report, as mentioned on NABL Website.

BTHPL/7.2/01

BHARAT TEST HOUSE PVT. LTD.

 1668(DIV-II), HSIIDC Industrial Estate, Rai, Distt. Sonapat, Haryana-131029
 Tel.: 0130-2974474 | Mob.: 8053000887, 8930260106 | email: bthrai@bharattesthouse.com

(1)The above results are related only to the Tests/Calibration performed on the product received. Endorsement of product is neither inferred nor implied. (2) This report is not to be reproduced wholly or in part & forbidden to be used as an evidence in the court law & ought not to be used in any advertising media without our special permission in writing. (3) Samples will be disposed after 30 days except perishable items (within 7days) from date of issue of report or as per the regulatory guidelines, if not collected or claimed by the customer. (4) Total liability of our Test House is limited to the invoice amount only. (5) Report refers to the product received by Bharat Test House Pvt. Ltd. unless mentioned otherwise.